


Denotes EPDM Roof area of building

Denotes area where EPDM has separated and work described in Allowance #1 will need to be completed. Actual limits of area to be determined in the field based on conditions observed at time of work

- Contractor to coordinate any work associated with installing new roofing around HVAC RTUs to include temporary lifting and removal, if needed.



Replace existing wooden access ladder with new steel ladder that meets current applicable rules and regulations

ROOF AREA IN SQ. FT.

Section 1	=	16175.0 sq.ft.
Section 2	=	3656.8 sq.ft.
Section 3	=	3856.4 sq.ft.
Section 4	=	211.2 sq.ft.
Total Roof Area	=	23899.4 sq.ft.

LEGEND

- AREAS WITH STEEL CATWALK
- AREAS WITH BARE AND/OR BLOWN FELTS
- AREAS WITH VEGETATION GROWTH
- AREAS WITH DEBRIS

ROOF PROJECTIONS


- | | | | |
|--|----------------------------------|--|----------------------------------|
| | ANTENNA | | HVAC UNIT ON SLEEPERS |
| | BREATHER | | LADDER |
| | CAPPED STACK | | LIGHT POST |
| | CHANGE IN ELEV. | | PIPE SUPPORT |
| | CHIMNEY | | PITCH POCKET |
| | CONDUIT LINE | | PLUMBING OR SOIL STACK |
| | CONTROL JOINT | | RA ROOF ANCHOR |
| | DRAIN | | SATELLITE DISH |
| | EXHAUST FAN ON CURB | | SCUPPER |
| | EXHAUST FAN | | SECURITY CAMERA |
| | EXPANSION JOINT | | SKYLIGHT |
| | EXPLOSION HATCH | | SLOPE |
| | FLAGPOLE | | SQUARE VENT |
| | GAS PIPELINE | | SQUARE VENT ON ON OVERSIZED CURB |
| | GOOSENECK VENT | | TALL CONE OR "B" VENT |
| | GOOSENECK VENT ON OVERSIZED CURB | | TALL CONE OR "B" VENT ON CURB |
| | HATCH | | VENT |
| | HVAC UNIT | | ROUND VENT |
| | HVAC UNIT ON CURB | | ANCHOR |
| | EMPTY CONC. BASE | | WALKWAY PADS |

NOTE: THE ROOFING CONTRACTOR SHALL BE RESPONSIBLE FOR SITE VERIFICATION OF ALL ROOF MEASUREMENTS


Bedford County Public Schools

TITLE: ROOF PLAN
 CLIENT: Huddleston Elementary
 PROJECT: Huddleston Elementary (Sec.1 to Sec.4)
 1027 Huddleston Dr.,
 Huddleston, VA 24104, USA

IRC #
 W.O. #
 SCALE: 1" = 17' 3"
 DATE: 28 November 2023
 DRN BY:
 CHK BY: BRIAN FOLEY



DWG #



ROOF AREA IN SQ. FT.	
Section 5	= 6620.4 sq.ft.
Section 6	= 2223.6 sq.ft.
Total Roof Area	= 8844.0 sq.ft.

LEGEND

- AREAS WITH STEEL CATWALK
- AREAS WITH BARE AND/OR BLOWN FELTS
- AREAS WITH VEGETATION GROWTH
- AREAS WITH DEBRIS

ROOF PROJECTIONS


- | | | | |
|--|----------------------------------|--|----------------------------------|
| | ANTENNA | | HVAC UNIT ON SLEEPERS |
| | BREATHER | | LADDER |
| | CAPPED STACK | | LIGHT POST |
| | CHANGE IN ELEV. | | PIPE SUPPORT |
| | CHIMNEY | | PITCH POCKET |
| | CONDUIT LINE | | PLUMBING OR SOIL STACK |
| | CONTROL JOINT | | RA ROOF ANCHOR |
| | DRAIN | | SATELLITE DISH |
| | EXHAUST FAN ON CURB | | SCUPPER |
| | EXHAUST FAN | | SECURITY CAMERA |
| | EXPANSION JOINT | | SKYLIGHT |
| | EXPLOSION HATCH | | SLOPE |
| | FLAGPOLE | | SQUARE VENT |
| | GAS PIPELINE | | SQUARE VENT ON ON OVERSIZED CURB |
| | GOOSENECK VENT | | TALL CONE OR "B" VENT |
| | GOOSENECK VENT ON OVERSIZED CURB | | TALL CONE OR "B" VENT ON CURB |
| | HATCH | | VENT |
| | HVAC UNIT | | ROUND VENT |
| | HVAC UNIT ON CURB | | ANCHOR |
| | EMPTY CONC. BASE | | WALKWAY PADS |

NOTE: THE ROOFING CONTRACTOR SHALL BE RESPONSIBLE FOR SITE VERIFICATION OF ALL ROOF MEASUREMENTS

Bedford County Public Schools

TITLE: ROOF PLAN
 CLIENT: Huddleston Elementary
 PROJECT: Huddleston Elementary (Sec.5 & Sec.6)
 1027 Huddleston Dr.,
 Huddleston, VA 24104, USA

IRC #
 W.O. #
 SCALE: 1" = 5' 9"
 DATE: 28 November 2023



DRN. BY:
 CHK. BY: BRIAN FOLEY

DWG. #